

Material Standards 890576.1 Certified PCB Tested Decal

Revision 0 Jun 15, 2012

1. Scope

This specification applies to flat-surfaced, Certified PCB tested decal similar to the illustrated example. These decals shall be designed for outdoor applications. Each decal shall be produced to allow information to be written on the face of the decal with all of the following instruments: pencil, ballpoint pen and waterproof marker.

2. Material and Tag Requirements

Refer to District Material Standard DECALMAT8.

3. Size

Decal shall be 5" high x 5" wide, with a tolerance of +/- 1/32".

4. Color

The front of the decal shall be UV Resistant Sericol 190 Process Blue with white reversed out copy.

5. Material ID Number and Identification

This specification applies to the following District Material ID Number: 890576, to be marked in the bottom right corner, with the bottom left corner containing the manufacturer's name and/or logo.

CERTIFIED The dielectric fluid in this ur has been laboratory tested for and found to be less than 50 p	nit PCB
Manufacturer	
Serial No.	
PCB (ppm)	
Test Date	
Test records may be obtained f Environmental Affairs Departn P.U.D. No. 1 of Snohomish Co P.O. Box 1107 Everett, WA 98206 425-783-1000 or 1-877-783-1	nent unty
Designer Dece, ec 1400-422-4333	Cat ID 890576