


TERMINAL BLOCK IN JUNCTION BOX AND CAPACITOR CONTROL PANEL

- 1 GROUND
- 2 PT HOT LEG
- 3 NEUTRAL
- 4 SPARE
- 5-6 SWITCH OPEN/CLOSE
- 7-8 SWITCH "C" CONTACT
- 9-10 CT INPUTS



CAPACITOR CONTROL WIRING DIAGRAM

**12.47KV SWITCHED CAPACITOR**  
CONTROL WIRING DIAGRAM

PUBLIC UTILITY DISTRICT NO. 1  
SNOHOMISH COUNTY -- EVERETT, WA

DRAWN	CHK'D	SCALE	ENGR.	DATE	REV	APPROVED	DRAWING
		NONE	ARP	10/18			B-1054